

Job Name _____

Purchaser _____

Submitted to _____

Unit Designation _____

Location _____

Engineer _____

Reference _____

Schedule # _____

Approval _____

Construction _____

Specifications

Model	US Code		RNS12ABT
	Model Number		AR12TSFABWKNCV
Performance	Nominal Capacity	Cooling (Btu/h)	12,000
		Heating (Btu/h)	12,000
Power	Voltage	Ø / V / Hz	1 / 208-230 / 60
	Operating Current (Max.)	Cooling (A)	0.4
		Heating (A)	0.4
Evaporator Fan	Type		BLDC motor with cross-flow fan
	Consumption	Watts	27 X 1
	FLA	Amps	0.12
Airflow	Air Volume (L/M/H/Turbo)	Cooling (CFM)	250 / 301 / 340 / 378
		Heating (CFM)	282 / 335 / 374 / 413
Refrigerant	Type		R410A
	Control Method		Electronic Expansion Valve (at outdoor unit)
Pipe Connections	Indoor & Outdoor	High side (flare)	1/4"
		Low side (flare)	3/8"
Dimensions	W X H X D (in.)	Indoor Unit	35 X 11 3/4 X 8 7/16
	Weight (lbs.)	Indoor Unit	23.4
	Condensate Connection		11/16" OD
Sound Pressure Level	Low / High	dB(A)	23 / 39
Accessories	Wired Controllers ¹	Advanced	MWR-WG00UN
		Simple Touch	MWR-SH11UN
	Wired Controller Sub-PCB		MIM-A00UN
	24VAC Thermostat Adapter		MIM-A60UN
	Condensate Pump	Aspen Mini Orange	ASP-MO-UNIV 110-250
		Blue Diamond	BD-BLUE-230
	External Temperature Sensor		MRW-TA
	External Contact Control Interface Module ²		MIM-B14
Line sets - insulated and flared, interconnect cables included		25' - ILS2506	
		50' - ILS5006	
Safety Certifications			ETL (UL 1995)



- General Information**
- The indoor unit shall feature "Wind-Free™" mode*. In cooling mode, as room temperature nears set temperature, the unit will close its louver and will disperse air into the space through thousands of micro-holes on the front of the indoor unit preventing cold air drafts on occupants.
 - The indoor unit shall have Wi-Fi capability as standard
 - The indoor unit shall be powered by the outdoor unit

- Construction**
- Indoor unit chassis shall be UL94 V0 with a galvanized steel mounting bracket
 - The indoor unit shall have easy-access to wire, pipe, and drain connections via access panel on the bottom of the unit for simple installation and service

- Heat Exchanger**
- The heat exchangers shall be mechanically bonded fin to copper tube

- Indoor Fan**
- The indoor fan shall be a single, antibacterial cross-flow type
 - Three fan speed settings and auto setting
 - Automatic (motorized) vertical swing (up/down) and horizontal swing (left/right) louvers

- Controls**
- The system shall have a built in Wi-Fi adapter as standard to allow control and monitoring using the Samsung SmartThings app (Android, iOS)
 - Dual set temperature support when connected to MWR-WG00UN Advanced Wired Controller.
 - The indoor unit shall have a simple connection for overflow detection devices or any other normally closed contact for simple unit shutdown
 - The indoor unit shall ship with a wireless controller, holder, and batteries
 - Wired controller options available

- Convenience**
- System energy consumption can be viewed using the Samsung SmartThings mobile app (not revenue grade, for reference only)
 - Auto Clean Function
 - 7-segment digital display on front of unit to display temperature and unit status
 - Auto changeover
 - Good sleep mode
 - Quiet mode
 - Dry mode
 - Simple ON/OFF time function – Using the wireless controller specify the ON and/or OFF times
 - Electro-static, washable, main filter as standard accessible from the top of unit
 - Filter cleaning reminder

Compatibility
Will only operate with Samsung outdoor unit model numbers:
AR12TSFABWKXCV (RXS12ABT), AJ020TXJ2CH/AA (JXH20J2T), AJ024TXJ3CH/AA (JXH24J3T), AJ036TXJ4CH/AA (JXH36J4T), AJ048TXJ5CH/AA (JXH48J5T), AJ020TXS3CH/AA (JXH20S3T), AJ024TXS4CH/AA (JXH24S4T), AJ030TXS4CH/AA (JXH30S4T), AJ036TXS4CH/AA (JXH36S4T)

*The Wind-Free™ unit delivers an air current that is under 0.15 m/s while in Wind-Free™ mode. Air velocity that is below 0.15 m/s is considered "still air" as defined by ASHRAE (American Society of Heating, Refrigerating, and Air-Conditioning Engineers).

¹ Sub-PCB model MIM-A00UN is required when connecting optional wired controllers

² When applying MIM-B14 external contact control interface module, MIM-A00UN wired controller sub-PCB is required.

Samsung HVAC maintains a policy of ongoing development, specifications are subject to change without notice. Refer to www.AHRIdirectory.org for current reference numbers.

MOUNTING PLATE